



4163A4Q2

间级线线间
那次是
A CONTRACTOR
1887/1888
国際25年20年6

PROJECT

TYPE

NOTES

QUANTITY

DATE












Wall surface luminaire made from aluminium; surface Bronze; powder coated; matt texture; RAL 075 30 10; direct light distribution; PCB 3step binning; phase-cut dim; light colour 2700 K; binning initial $MacAdam \leq 3 SDCM; CRI \geq 80; 220 - 240 V; degree of protection$ IP65; Class 1; driver included; light source not replaceable; control gear replaceable by end-user;



Luminaire

Wall
Surface
Bronze
RAL 075 30 10 ^a
IP65
Exterior
745 lm

LED Module

2700 K
CRI ≥ 80
L80 / 60000 h
≤ 3 SDCM (initial MacAdam)
746 lm
73 lm/W ^b

Optical

Asymetric			
CIE flux code:	31 55	75 (0 100

Electrical


phase-cut dim	
220 - 240 V	
system 10.2 W	
Class 1	

Physical

length 130 mm	
width 100 mm	
height 30 mm	
0.75 kg	

^a Colour may deviate slightly due to production conditions

LIGHT DISTRIBUTION



^b Without electrical and optical losses



PALOS WALL 3.0

4163A4Q2



Maintenance Factor

Operating Time [h]	10.000	20.000	30.000	40.000	50.000
LLMF	0.97	0.93	0.89	0.86	0.82
LSF	1	1	1	1	<u> </u>

MF	LMF × RSMF × LLMF × LSF	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^aAccording to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.